



Project Activity Report

Chelsea Alarm Company
 482 N. Cambridge Ave.
 Merrysville, MI 47141
 Phone: 812-555-5527
 Fax: 812-555-4456
 Email: info@codepalinspections.com

PRJ-09-0014
Mariners Golf Course - 2009
 Alarm System On-Location
 Start Date: 1/1/2009 End Date: 12/31/2009

False Alarm (EPS)

Maintenance Garage 1020 N Jamison Lane Zone 3

Number	Record Type	Date	Cause	Complete	Violation Count	Corrected Violations	Inspector
AST-JMMC-09-0001	False Alarm (EPS)	07/23/2009 12:00 am	Alarm Tripped	Yes	0	0	John McMercer

Checklist Summary

Fire Alarm System - EPS

Mariners Clubhouse 1020 N Jamison Lane Zone 1

Number	Record Type	Date	Cause	Complete	Violation Count	Corrected Violations	Inspector
D&AS-E-JMMC-09-0001	Fire Alarm System - EPS	04/01/2009 12:00 am	Periodic	Yes	0	0	John McMercer

Mariners Resaurant 1020 N Jamison Lane Zone 2

Number	Record Type	Date	Cause	Complete	Violation Count	Corrected Violations	Inspector
D&AS-E-JMMC-09-0001	Fire Alarm System - EPS	06/01/2009 12:00 am	Periodic	No	0	0	John McMercer

Checklist Summary

Fire Alarm

HEAT DETECTORS - NUMBER TESTED:

Answer	Occurances
5	2

HEAT DETECTORS CIRCUIT RESISTANCE:

Answer	Occurances
10	2

MANUAL FIRE PULL - NUMBER TESTED:

Answer	Occurances
10	2

SMOKE DETECTORS - NUMBER TESTED:

Answer	Occurances
10	2

SMOKE SENSITIVITY TESTED - NUMBER TESTED:

Answer	Occurances
10	2

	Positive	Negative	N/A
HEAT DETECTORS:	2	0	0
MANUAL FIRE PULL:	2	0	0
SMOKE DETECTORS:	2	0	0
SMOKE SENSITIVITY TESTED:	2	0	0

Footer

KEYPAD NUMBER:

<u>Answer</u>	<u>Occurances</u>			
12564545	4			
		<u>Positive</u>	<u>Negative</u>	<u>N/A</u>
DISCONNECTED AUDIBLES:	2	2	0	0
RECONNECTED AUDIBLES:	2	2	0	0
TURNUED KEYPAD BACK:	2	2	0	0
TURNUED KEYPAD DOWN:	2	2	0	0

General

CHARGING CIRCUIT VOLTS:

<u>Answer</u>	<u>Occurances</u>
120	2

EMERGENCY POWER SUPPLY VOLTS:

<u>Answer</u>	<u>Occurances</u>			
12-	1			
		<u>Positive</u>	<u>Negative</u>	<u>N/A</u>
DID ALL TROUBLE SIGNALS OPERATE PROPERLY?:	2	2	0	0
DISCONNECTED A.C. IN TESTING STANDBY POWER:	1	1	0	0
EMERGENCY POWER SUPPLY:	1	1	0	0
RECONNECTED A.C.:	2	2	0	0

Alarm System Repair

Mariners Clubhouse 1020 N Jamison Lane Zone 1

<u>Number</u>	<u>Record Type</u>	<u>Date</u>	<u>Cause</u>	<u>Complete</u>	<u>Violation Count</u>	<u>Corrected Violations</u>	<u>Inspector</u>
-E-JMMC-09-0002.S001-	Alarm System Repair	04/02/2009 12:00 am	Failed Inspection	Yes	0	1	John McMercer

Checklist Summary

Total Number of Records: 4
Total Hrs. To Complete: 9.08