



## Project Inspector Report

Chelsea Alarm Company  
 482 N. Cambridge Ave.  
 Merrysville, MI 47141  
 Phone: 812-555-5527  
 Fax: 812-555-4456

Email: info@codepalinspections.com

**PRJ-09-0014**  
**Mariners Golf Course - 2009**  
 Alarm System On-Location  
 Start Date: 1/1/2009 End Date: 12/31/2009

**Inspector: John McMercer**

<u>Activity Number</u>	<u>Hours</u>	<u>Complete</u>	<u>Address</u>
AST-JMMC-09-0001	1.00	True	1020 N Jamison Lane Zone 3

<u>Activity Number</u>	<u>Hours</u>	<u>Complete</u>	<u>Address</u>
FD&AS-E-JMMC-09-0	4.83	True	1020 N Jamison Lane Zone 1

Sub Activities

<u>Number</u>	<u>Hours</u>	<u>Complete</u>	<u>Description</u>	<u>Item Type</u>	<u>Result</u>	<u>Location</u>
FD&AS-E-JMMC-09-0002.S0001		Yes	Wall Mount Annunciator	Annunciator		Electical Room
FD&AS-E-JMMC-09-0002.S0002		Yes	Honeywell Battery Backup Power Supply	Emergency Power Supply (EPS)		Electical Room
FD&AS-E-JMMC-09-0002.S0003		Yes	Control Unit Battery	Battery		Electical Room
FD&AS-E-JMMC-09-0002.S0004		Yes	Honeywell Manual Pull Station	Manual Fire Pull (EPS)		Managers Office
FD&AS-E-JMMC-09-0002.S0005		Yes	Honeywell Manual Pull Station	Manual Fire Pull (EPS)		Pro Shop North
FD&AS-E-JMMC-09-0002.S0006		Yes	Honeywell Manual Pull Station	Manual Fire Pull (EPS)		Pro Shop South
FD&AS-E-JMMC-09-0002.S0007		Yes	Honeywell Manual Pull Station	Manual Fire Pull (EPS)		Break Room
FD&AS-E-JMMC-09-0002.S0008		Yes	Honeywell Manual Pull Station	Manual Fire Pull (EPS)		Registration Desk
FD&AS-E-JMMC-09-0002.S0009		Yes	Honeywell Manual Pull Station	Manual Fire Pull (EPS)		Excercise Room
FD&AS-E-JMMC-09-0002.S0010		Yes	Honeywell Manual Pull Station	Manual Fire Pull (EPS)		Lounge West
FD&AS-E-JMMC-09-0002.S0011		Yes	Honeywell Manual Pull Station	Manual Fire Pull (EPS)		Lounge East
FD&AS-E-JMMC-09-0002.S0012		Yes	Honeywell Manual Pull Station	Manual Fire Pull (EPS)		Mens Restroom
FD&AS-E-JMMC-09-0002.S0013		Yes	Honeywell Manual Pull Station	Manual Fire Pull (EPS)		Womens Restroom
FD&AS-E-JMMC-09-0002.S0014	1:45	Yes	Honeywell Control Panel	Control Unit	Fail	Electical Room
FD&AS-E-JMMC-09-0002.S0015		Yes	Honeywell Waterflow Switch	Fire Alarm - Waterflow		Electical Room
FD&AS-E-JMMC-09-0002.S0016		Yes	Honeywell Waterflow Switch	Fire Alarm - Waterflow		Pro Shop North
FD&AS-E-JMMC-09-0002.S0017		Yes	Honeywell Waterflow Switch	Fire Alarm - Waterflow		Managers Office
FD&AS-E-JMMC-09-0002.S0018		Yes	Honeywell Waterflow Switch	Fire Alarm - Waterflow		Registration Desk
FD&AS-E-JMMC-09-0002.S0019		Yes	Honeywell Waterflow Switch	Fire Alarm - Waterflow		Excercise Room
FD&AS-E-JMMC-09-0002.S0020		Yes	Honeywell Sequential Display	Sequential Display		Electical Room
FD&AS-E-JMMC-09-0002.S0021		Yes	Honeywell Ion Duct Detector	Duct Detector (EPS)		Excercise Room
FD&AS-E-JMMC-09-0002.S0022		Yes	Honeywell Ion Duct Detector	Duct Detector (EPS)		Mens Restroom
FD&AS-E-JMMC-09-0002.S0023		Yes	Honeywell Ion Duct Detector	Duct Detector (EPS)		Lounge East
FD&AS-E-JMMC-09-0002.S0024		Yes	Honeywell Ion Duct Detector	Duct Detector (EPS)		Womens Restroom
FD&AS-E-JMMC-09-0002.S0025		Yes	Honeywell Ion Duct Detector	Duct Detector (EPS)		Registration Desk
FD&AS-E-JMMC-09-0002.S0026		Yes	Honeywell Heat Detector	Heat Detector (EPS)		Excercise Room
FD&AS-E-JMMC-09-0002.S0027		Yes	Honeywell Heat Detector	Heat Detector (EPS)		Lounge East

**Inspector: John McMercer**

FD&AS-E-JMMC-09-0002.S0028	Yes	Honeywell Heat Detector	Heat Detector (EPS)	Electical Room
FD&AS-E-JMMC-09-0002.S0029	Yes	Honeywell Heat Detector	Heat Detector (EPS)	Pro Shop North
FD&AS-E-JMMC-09-0002.S0030	Yes	Honeywell Heat Detector	Heat Detector (EPS)	Registration Desk
FD&AS-E-JMMC-09-0002.S0031	Yes	Honeywell Voice Unit	Voice Unit	Electical Room
FD&AS-E-JMMC-09-0002.S0032	Yes	Honeywell Horn	Horn (EPS)	Lounge East
FD&AS-E-JMMC-09-0002.S0033	Yes	Honeywell Horn	Horn (EPS)	Excercise Room
FD&AS-E-JMMC-09-0002.S0034	Yes	Honeywell Horn	Horn (EPS)	Lounge West
FD&AS-E-JMMC-09-0002.S0035	Yes	Honeywell Horn	Horn (EPS)	Registration Desk
FD&AS-E-JMMC-09-0002.S0036	Yes	Honeywell Horn	Horn (EPS)	Managers Office
FD&AS-E-JMMC-09-0002.S0037	Yes	Honeywell Horn	Horn (EPS)	Break Room
FD&AS-E-JMMC-09-0002.S0038	Yes	Honeywell Horn	Horn (EPS)	Pro Shop South
FD&AS-E-JMMC-09-0002.S0039	Yes	Honeywell Horn	Horn (EPS)	Mens Restroom
FD&AS-E-JMMC-09-0002.S0040	Yes	Honeywell Horn	Horn (EPS)	Womens Restroom
FD&AS-E-JMMC-09-0002.S0041	Yes	Honeywell Horn	Horn (EPS)	Pro Shop North
FD&AS-E-JMMC-09-0002.S0042	Yes	Honeywell Supervisory Signal	Supervisory Signal	Electical Room
FD&AS-E-JMMC-09-0002.S0043	Yes	Honeywell Smoke Detector	Smoke Detector (EPS)	Excercise Room
FD&AS-E-JMMC-09-0002.S0044	Yes	Honeywell Smoke Detector	Smoke Detector (EPS)	Registration Desk
FD&AS-E-JMMC-09-0002.S0045	Yes	Honeywell Smoke Detector	Smoke Detector (EPS)	Managers Office
FD&AS-E-JMMC-09-0002.S0046	Yes	Honeywell Smoke Detector	Smoke Detector (EPS)	Pro Shop South
FD&AS-E-JMMC-09-0002.S0047	Yes	Honeywell Smoke Detector	Smoke Detector (EPS)	Womens Restroom
FD&AS-E-JMMC-09-0002.S0048	Yes	Honeywell Smoke Detector	Smoke Detector (EPS)	Pro Shop North
FD&AS-E-JMMC-09-0002.S0049	Yes	Honeywell Smoke Detector	Smoke Detector (EPS)	Electical Room
FD&AS-E-JMMC-09-0002.S0050	Yes	Honeywell Smoke Detector	Smoke Detector (EPS)	Lounge East
FD&AS-E-JMMC-09-0002.S0051	Yes	Honeywell Smoke Detector	Smoke Detector (EPS)	Lounge West
FD&AS-E-JMMC-09-0002.S0052	Yes	Honeywell Smoke Detector	Smoke Detector (EPS)	Mens Restroom
FD&AS-E-JMMC-09-0002.S0053	Yes	Honeywell Smoke Detector	Smoke Detector (EPS)	Break Room
FD&AS-E-JMMC-09-0002.S0054	Yes	Honeywell Remote Trouble Unit	Remote Trouble Unit	Electical Room
FD&AS-E-JMMC-09-0002.S0055	Yes	Honeywell Strobe	Strobe (EPS)	Lounge West
FD&AS-E-JMMC-09-0002.S0056	Yes	Honeywell Strobe	Strobe (EPS)	Womens Restroom
FD&AS-E-JMMC-09-0002.S0057	Yes	Honeywell Strobe	Strobe (EPS)	Mens Restroom
FD&AS-E-JMMC-09-0002.S0058	Yes	Honeywell Strobe	Strobe (EPS)	Excercise Room
FD&AS-E-JMMC-09-0002.S0059	Yes	Honeywell Strobe	Strobe (EPS)	Lounge East
FD&AS-E-JMMC-09-0002.S0060	Yes	Honeywell Strobe	Strobe (EPS)	Registration Desk
FD&AS-E-JMMC-09-0002.S0061	Yes	Honeywell Strobe	Strobe (EPS)	Pro Shop North
FD&AS-E-JMMC-09-0002.S0062	Yes	Honeywell Strobe	Strobe (EPS)	Managers Office
FD&AS-E-JMMC-09-0002.S0063	Yes	Honeywell Strobe	Strobe (EPS)	Break Room
FD&AS-E-JMMC-09-0002.S0064	Yes	Honeywell Strobe	Strobe (EPS)	Pro Shop South

**Sub Activity Total Hours: 1.75**

<u>Activity Number</u>	<u>Hours</u>	<u>Complete</u>	<u>Address</u>
FD&AS-E-JMMC-09-C	2.25	True	1020 N Jamison Lane Zone 1

Activity Number	Hours	Complete	Address
FD&AS-E-JMMC-09-0	1.00	False	1020 N Jamison Lane Zone 2

## Sub Activities

Number	Hours	Complete	Description	Item Type	Result	Location
FD&AS-E-JMMC-09-0003.S0001		Yes	Honeywell Annunciator	Annunciator	Pass	Electical Room
FD&AS-E-JMMC-09-0003.S0002		Yes	Honeywell Battery Backup Power Supply	Emergency Power Supply (EPS)	Pass	Electical Room
FD&AS-E-JMMC-09-0003.S0003		Yes	Alarm Battery	Battery	Pass	Electical Room
FD&AS-E-JMMC-09-0003.S0004		Yes	Honeywell Manual Pull Station	Manual Fire Pull (EPS)	Pass	Managers Office
FD&AS-E-JMMC-09-0003.S0005		Yes	Honeywell Manual Pull Station	Manual Fire Pull (EPS)	Pass	Dining Room West
FD&AS-E-JMMC-09-0003.S0006		Yes	Honeywell Manual Pull Station	Manual Fire Pull (EPS)	Pass	Mens Restroom
FD&AS-E-JMMC-09-0003.S0007		Yes	Honeywell Manual Pull Station	Manual Fire Pull (EPS)	Pass	Dining Room North
FD&AS-E-JMMC-09-0003.S0008		Yes	Honeywell Manual Pull Station	Manual Fire Pull (EPS)	Pass	Commercial Kitchen - East
FD&AS-E-JMMC-09-0003.S0009		Yes	Honeywell Manual Pull Station	Manual Fire Pull (EPS)	Pass	Dining Room East
FD&AS-E-JMMC-09-0003.S0010		Yes	Honeywell Manual Pull Station	Manual Fire Pull (EPS)	Pass	Dining Room South
FD&AS-E-JMMC-09-0003.S0011		Yes	Honeywell Manual Pull Station	Manual Fire Pull (EPS)	Pass	Womens Restroom
FD&AS-E-JMMC-09-0003.S0012		Yes	Honeywell Manual Pull Station	Manual Fire Pull (EPS)	Pass	Commercial Kitchen - West
FD&AS-E-JMMC-09-0003.S0013		No	Honeywell Control Panel	Control Unit	Pass	Electical Room
FD&AS-E-JMMC-09-0003.S0014		Yes	Honeywell Waterflow Switch	Fire Alarm - Waterflow	Pass	Commercial Kitchen - East
FD&AS-E-JMMC-09-0003.S0015		Yes	Honeywell Waterflow Switch	Fire Alarm - Waterflow	Pass	Mens Restroom
FD&AS-E-JMMC-09-0003.S0016		Yes	Honeywell Waterflow Switch	Fire Alarm - Waterflow	Pass	Dining Room East
FD&AS-E-JMMC-09-0003.S0017		Yes	Honeywell Sequential Display	Sequential Display	Pass	Electical Room
FD&AS-E-JMMC-09-0003.S0018		Yes	Honeywell Ion Duct Detector	Duct Detector (EPS)	Pass	Dining Room North
FD&AS-E-JMMC-09-0003.S0019		Yes	Honeywell Ion Duct Detector	Duct Detector (EPS)	Pass	Mens Restroom
FD&AS-E-JMMC-09-0003.S0020		Yes	Honeywell Ion Duct Detector	Duct Detector (EPS)	Pass	Commercial Kitchen - West
FD&AS-E-JMMC-09-0003.S0021		Yes	Honeywell Ion Duct Detector	Duct Detector (EPS)	Pass	Commercial Kitchen - East
FD&AS-E-JMMC-09-0003.S0022		Yes	Honeywell Ion Duct Detector	Duct Detector (EPS)	Pass	Electical Room
FD&AS-E-JMMC-09-0003.S0023		Yes	Honeywell Heat Detector	Heat Detector (EPS)	Pass	Dining Room North
FD&AS-E-JMMC-09-0003.S0024		Yes	Honeywell Heat Detector	Heat Detector (EPS)	Pass	Commercial Kitchen - West
FD&AS-E-JMMC-09-0003.S0025		Yes	Honeywell Heat Detector	Heat Detector (EPS)	Pass	Mens Restroom
FD&AS-E-JMMC-09-0003.S0026		Yes	Honeywell Heat Detector	Heat Detector (EPS)	Pass	Commercial Kitchen - East
FD&AS-E-JMMC-09-0003.S0027		Yes	Honeywell Heat Detector	Heat Detector (EPS)	Pass	Electical Room
FD&AS-E-JMMC-09-0003.S0028		Yes	Honeywell Voice Unit	Voice Unit	Pass	Electical Room
FD&AS-E-JMMC-09-0003.S0029		Yes	Honeywell Horn	Horn (EPS)	Pass	Commercial Kitchen - East
FD&AS-E-JMMC-09-0003.S0030		Yes	Honeywell Horn	Horn (EPS)	Pass	Womens Restroom
FD&AS-E-JMMC-09-0003.S0031		Yes	Honeywell Horn	Horn (EPS)	Pass	Commercial Kitchen - West
FD&AS-E-JMMC-09-0003.S0032		Yes	Honeywell Horn	Horn (EPS)	Pass	Dining Room East
FD&AS-E-JMMC-09-0003.S0033		Yes	Honeywell Horn	Horn (EPS)	Pass	Dining Room North
FD&AS-E-JMMC-09-0003.S0034		Yes	Honeywell Horn	Horn (EPS)	Pass	Dining Room South
FD&AS-E-JMMC-09-0003.S0035		Yes	Honeywell Horn	Horn (EPS)	Pass	Dining Room West
FD&AS-E-JMMC-09-0003.S0036		Yes	Honeywell Horn	Horn (EPS)	Pass	Mens Restroom
FD&AS-E-JMMC-09-0003.S0037		Yes	Honeywell Horn	Horn (EPS)	Pass	Managers Office
FD&AS-E-JMMC-09-0003.S0038		Yes	Honeywell Supervisory Signal	Supervisory Signal	Pass	Electical Room
FD&AS-E-JMMC-09-0003.S0039		Yes	Honeywell Smoke Detector	Smoke Detector (EPS)	Pass	Dining Room South

**Inspector: John McMercer**

FD&AS-E-JMMC-09-0003.S0040	Yes	Honeywell Smoke Detector	Smoke Detector (EPS)	Pass	Dining Room North
FD&AS-E-JMMC-09-0003.S0041	Yes	Honeywell Smoke Detector	Smoke Detector (EPS)	Pass	Commercial Kitchen - West
FD&AS-E-JMMC-09-0003.S0042	Yes	Honeywell Smoke Detector	Smoke Detector (EPS)	Pass	Commercial Kitchen - East
FD&AS-E-JMMC-09-0003.S0043	Yes	Honeywell Smoke Detector	Smoke Detector (EPS)	Pass	Managers Office
FD&AS-E-JMMC-09-0003.S0044	Yes	Honeywell Smoke Detector	Smoke Detector (EPS)	Pass	Dining Room West
FD&AS-E-JMMC-09-0003.S0045	Yes	Honeywell Smoke Detector	Smoke Detector (EPS)	Pass	Dining Room East
FD&AS-E-JMMC-09-0003.S0046	Yes	Honeywell Smoke Detector	Smoke Detector (EPS)	Pass	Mens Restroom
FD&AS-E-JMMC-09-0003.S0047	Yes	Honeywell Smoke Detector	Smoke Detector (EPS)	Pass	Womens Restroom
FD&AS-E-JMMC-09-0003.S0048	Yes	Honeywell Remote Trouble Unit	Remote Trouble Unit	Pass	Electical Room
FD&AS-E-JMMC-09-0003.S0049	Yes	Honeywell Strobe	Strobe (EPS)	Pass	Commercial Kitchen - East
FD&AS-E-JMMC-09-0003.S0050	Yes	Honeywell Strobe	Strobe (EPS)	Pass	Commercial Kitchen - West
FD&AS-E-JMMC-09-0003.S0051	Yes	Honeywell Strobe	Strobe (EPS)	Pass	Dining Room West
FD&AS-E-JMMC-09-0003.S0052	Yes	Honeywell Strobe	Strobe (EPS)	Pass	Dining Room South
FD&AS-E-JMMC-09-0003.S0053	Yes	Honeywell Strobe	Strobe (EPS)	Pass	Dining Room North
FD&AS-E-JMMC-09-0003.S0054	Yes	Honeywell Strobe	Strobe (EPS)	Pass	Dining Room East
FD&AS-E-JMMC-09-0003.S0055	Yes	Honeywell Strobe	Strobe (EPS)	Pass	Womens Restroom
FD&AS-E-JMMC-09-0003.S0056	Yes	Honeywell Strobe	Strobe (EPS)	Pass	Mens Restroom
FD&AS-E-JMMC-09-0003.S0057	Yes	Honeywell Strobe	Strobe (EPS)	Pass	Managers Office

**Sub Activity Total Hours:**

<b>John McMercer Activity Totals</b>	
<b>Sub Activity Totals:</b>	<b>1.75</b>
<b>Primary Activity Totals:</b>	<b>9.08</b>
<b>Total:</b>	<b>10.83</b>

<b>Project Activity Totals</b>	
<b>Sub Activity Totals:</b>	<b>1.75</b>
<b>Primary Activity Totals:</b>	<b>9.08</b>
<b>Total:</b>	<b>10.83</b>
<b>3 of 4 Complete</b>	