



Project Activity Report

Barrington Systems - Sprinklers
 97882 Farmers Drive
 Barrington, MA 02619

Sprinkler System Quarterly

Evanston Northwest Hospital 2650 S Ridge Ground Floor

<u>Number</u>	<u>Record Type</u>	<u>Date</u>	<u>Cause</u>	<u>Complete</u>	<u>Violation Count</u>	<u>Corrected Violations</u>	<u>Inspector</u>
I-0001-08-0003	Sprinkler System Quarterly	07/28/2008 12:00 am	Periodic	Yes	1	0	Jeffry Boustra

Evanston Northwest Hospital 2650 S Ridge Penthouse

<u>Number</u>	<u>Record Type</u>	<u>Date</u>	<u>Cause</u>	<u>Complete</u>	<u>Violation Count</u>	<u>Corrected Violations</u>	<u>Inspector</u>
I-0001-08-0004	Sprinkler System Quarterly	07/28/2008 12:00 am	Periodic	No	1	0	Jeffry Boustra

Evanston Northwest Hospital 2650 S Ridge Third Floor

<u>Number</u>	<u>Record Type</u>	<u>Date</u>	<u>Cause</u>	<u>Complete</u>	<u>Violation Count</u>	<u>Corrected Violations</u>	<u>Inspector</u>
I-0001-08-0006	Sprinkler System Quarterly	07/28/2008 12:00 am	Periodic	Yes	1	0	Jeffry Boustra

Evanston Northwest Hospital 2650 S Ridge Second Floor

<u>Number</u>	<u>Record Type</u>	<u>Date</u>	<u>Cause</u>	<u>Complete</u>	<u>Violation Count</u>	<u>Corrected Violations</u>	<u>Inspector</u>
I-0001-08-0008	Sprinkler System Quarterly	07/28/2008 12:00 am	Periodic	Yes	0	0	Jeffry Boustra

Evanston Northwest Hospital 2650 S Ridge Fourth Floor

<u>Number</u>	<u>Record Type</u>	<u>Date</u>	<u>Cause</u>	<u>Complete</u>	<u>Violation Count</u>	<u>Corrected Violations</u>	<u>Inspector</u>
I-0001-08-0009	Sprinkler System Quarterly	07/28/2008 12:00 am	Periodic	Yes	0	0	Jeffry Boustra

Evanston Northwest Hospital 2650 S Ridge Basement

<u>Number</u>	<u>Record Type</u>	<u>Date</u>	<u>Cause</u>	<u>Complete</u>	<u>Violation Count</u>	<u>Corrected Violations</u>	<u>Inspector</u>
I-0001-08-0010	Sprinkler System Quarterly	07/28/2008 12:00 am	Periodic	Yes	0	0	Jeffry Boustra

Evanston Northwest Hospital 2650 S Ridge Sub-Basement

<u>Number</u>	<u>Record Type</u>	<u>Date</u>	<u>Cause</u>	<u>Complete</u>	<u>Violation Count</u>	<u>Corrected Violations</u>	<u>Inspector</u>
I-0001-08-0011	Sprinkler System Quarterly	07/28/2008 12:00 am	Periodic	Yes	0	0	Jeffry Boustra

Checklist Summary

General Main

	<u>Positive</u>	<u>Negative</u>	<u>N/A</u>
Are all systems in service?	5	0	0
Does all electrical heat tape appear to be satisfactory?	4	0	1
Does the hand hose on the sprinkler system(s) appear to be satisfactory?	3	1	1
<u>Resolution</u>	<u>Occurrences</u>		
Replace hand hose.	1		

Is there a minimum 18 clearance (457mm) between the top of the storage	4	1	0
Is the building occupied?	5	0	0

Owner's Section

Describe Any Fires Since Last Inspection

<u>Answer</u>	<u>Occurrences</u>
N/A	6

Describe Fire Protection Modifications Made Since Last Inspection

<u>Answer</u>	<u>Occurrences</u>
N/A	6

Expalin Any Occupancy Hazard Changes Since the Previous Inspection

<u>Answer</u>	<u>Occurrences</u>
N/A	6

When Was the Dry Piping System Last Checked for Proper Pitch

<u>Answer</u>	<u>Occurrences</u>
N/A	5

When Was the System Piping Last Checked for Stoppage, Corrosion, or F

<u>Answer</u>	<u>Occurrences</u>
N/A	5

	<u>Positive</u>	<u>Negative</u>	<u>N/A</u>
Are Dry Valves Adequately Protected From Freezing	4	1	1

<u>Resolution</u>	<u>Occurrences</u>
Windows need repair to protect from freezing.	1

Annual Inspection

Adams County Hospital 2650 S Ridge First Floor
--

<u>Number</u>	<u>Record Type</u>	<u>Date</u>	<u>Cause</u>	<u>Complete</u>	<u>Violation Count</u>	<u>Corrected Violations</u>	<u>Inspector</u>
I-0001-08-0007	Annual Inspection	07/28/2008 12:00 am	General	Yes	0	0	Jeffry Boustra

Checklist Summary

Total Number of Records: 8
Total Hrs. To Complete: 11.00