



## Project Inspector Report

Acme Alarm Company  
 3221 East Street  
 Springfield, IL 62711  
 Phone: (217) 787-1133  
 Fax: (217) 787-1171

**Inspector: Bob Lee**

<u>InspectionNumber</u>	<u>Hours</u>	<u>Complete</u>	<u>Address</u>
I-BL-08-0001	1.50	True	2333 Broadway Street Basement

### Sub Activities

<u>Number</u>	<u>Hours</u>	<u>Complete</u>	<u>Description</u>	<u>ItemType</u>	<u>Result</u>	<u>Location</u>
I-BL-08-0001.S0001	0:20	Yes	ABC Battery	Battery	Pass	Basement
I-BL-08-0001.S0002	0:20	Yes	Wet/Dry Valve 1	Tamper Before Backflow	Fail	Basement
I-BL-08-0001.S0003	0:20	Yes	Wet/Dry Valve 2	Tamper After Backflow	Fail	Basement
I-BL-08-0001.S0004	0:15	Yes	SD 04	Smoke Detector	Pass	SE Open Area
I-BL-08-0001.S0005	0:15	Yes	SD 05	Smoke Detector	Fail	Basement North
I-BL-08-0001.S0006	0:15	Yes	SD 06	Smoke Detector	Pass	Basement North
I-BL-08-0001.S0007	0:15	Yes	SD 07	Smoke Detector	Pass	Basement North
I-BL-08-0001.S0008	0:15	Yes	SD 08	Smoke Detector	Pass	Basement South
I-BL-08-0001.S0009	0:15	Yes	SD 09	Smoke Detector	Fail	Basement South
I-BL-08-0001.S0010	0:15	Yes	SD 10	Smoke Detector	Pass	Basement South
I-BL-08-0001.S0011	0:15	Yes	SD 11	Smoke Detector	Pass	West Tunnel
I-BL-08-0001.S0012	0:15	Yes	SD 12	Smoke Detector	Pass	Center Crawl
I-BL-08-0001.S0013	0:15	Yes	SD 13	Smoke Detector	Fail	East Tunnel
I-BL-08-0001.S0014	0:15	Yes	SD 14	Smoke Detector	Pass	East Crawl
I-BL-08-0001.S0015	0:15	Yes	PS 15	Pull Station	Fail	Basement Exit

**Total Hours: 4.00**

<u>InspectionNumber</u>	<u>Hours</u>	<u>Complete</u>	<u>Address</u>
I-BL-08-0002	1.00	True	2333 Broadway Street Main

### Sub Activities

<u>Number</u>	<u>Hours</u>	<u>Complete</u>	<u>Description</u>	<u>ItemType</u>	<u>Result</u>	<u>Location</u>
I-BL-08-0002.S0001	0:15	Yes	SD 71	Smoke Detector	Pass	NW Open Area
I-BL-08-0002.S0002	0:15	Yes	SD 70	Smoke Detector	Pass	NW Open Area
I-BL-08-0002.S0003	0:15	Yes	SD 69	Smoke Detector	Pass	Kitchen
I-BL-08-0002.S0004	0:15	Yes	SD 68	Smoke Detector	Pass	Top Basement Stairwell
I-BL-08-0002.S0005	0:15	Yes	SD 67	Smoke Detector	Pass	Receptionist Bathroom
I-BL-08-0002.S0006	0:15	Yes	SD 65	Smoke Detector	Pass	Receptionist Bathroom
I-BL-08-0002.S0007	0:15	Yes	SD 64	Smoke Detector	Pass	Phone Closet B
I-BL-08-0002.S0008	0:15	Yes	SD 63	Smoke Detector	Fail	Receptionist Bathroom
I-BL-08-0002.S0009	0:15	Yes	SD 62	Smoke Detector	Pass	Receptionist Bathroom
I-BL-08-0002.S0010	0:15	Yes	SD 61	Smoke Detector	Pass	Receptionist Closet
I-BL-08-0002.S0011	0:15	Yes	SD 60	Smoke Detector	Pass	SW Open Area
I-BL-08-0002.S0012	0:15	Yes	SD 59	Smoke Detector	Pass	SW Open Area
I-BL-08-0002.S0013	0:15	Yes	SD 58	Smoke Detector	Fail	SW Open Area
I-BL-08-0002.S0014	0:15	Yes	SD 57	Smoke Detector	Pass	NW Open Area
I-BL-08-0002.S0015	0:15	Yes	SD 56	Smoke Detector	Pass	NW Open Area
I-BL-08-0002.S0016	0:15	Yes	SD 55	Smoke Detector	Pass	Office #16
I-BL-08-0002.S0017	0:15	Yes	SD 54	Smoke Detector	Fail	Office #18
I-BL-08-0002.S0018	0:15	Yes	SD 53	Smoke Detector	Pass	Office #19
I-BL-08-0002.S0019	0:15	Yes	SD 52	Smoke Detector	Pass	Office #20
I-BL-08-0002.S0020	0:15	Yes	SD 51	Smoke Detector	Fail	NW Open Area
I-BL-08-0002.S0021	0:15	Yes	SD 50	Smoke Detector	Pass	Office #23
I-BL-08-0002.S0022	0:15	Yes	SD 49	Smoke Detector	Pass	Office #24
I-BL-08-0002.S0023	0:15	Yes	SD 48	Smoke Detector	Pass	Office #25
I-BL-08-0002.S0024	0:15	Yes	SD 47	Smoke Detector	Pass	Office #26
I-BL-08-0002.S0025	0:15	Yes	SD 46	Smoke Detector	Pass	Executive Secretary Office

**Inspector: Bob Lee**

I-BL-08-0002.S0026	0:15	Yes	SD 45	Smoke Detector	Pass	East BB's Office
I-BL-08-0002.S0027	0:15	Yes	SD 44	Smoke Detector	Pass	West BB's Office
I-BL-08-0002.S0028	0:15	Yes	SD 43	Smoke Detector	Pass	BB's Bathroom
I-BL-08-0002.S0029	0:15	Yes	SD 42	Smoke Detector	Pass	West Executive Conference Room
I-BL-08-0002.S0030	0:15	Yes	SD 41	Smoke Detector	Pass	East Executive Conference Room
I-BL-08-0002.S0031	0:15	Yes	SD 40	Smoke Detector	Fail	Secured File Room
I-BL-08-0002.S0032	0:15	Yes	SD 39	Smoke Detector	Pass	NW Electrical Room
I-BL-08-0002.S0033	0:15	Yes	SD 38	Smoke Detector	Pass	NW Area Above Ceiling
I-BL-08-0002.S0034	0:15	Yes	SD 37	Smoke Detector	Pass	Reception Area Above Ceiling
I-BL-08-0002.S0035	0:15	Yes	SD 36	Smoke Detector	Pass	NE Area Above Ceiling
I-BL-08-0002.S0036	0:15	Yes	SD 35	Smoke Detector	Fail	Receptionist Area
I-BL-08-0002.S0037	0:15	Yes	SD 34	Smoke Detector	Pass	NE Open Area
I-BL-08-0002.S0038	0:15	Yes	SD 33	Smoke Detector	Pass	NE Open Area
I-BL-08-0002.S0039	0:15	Yes	SD 32	Smoke Detector	Pass	NE Open Area
I-BL-08-0002.S0040	0:15	Yes	SD 31	Smoke Detector	Pass	NE Open Area
I-BL-08-0002.S0041	0:15	Yes	SD 30	Smoke Detector	Pass	NE Open Area
I-BL-08-0002.S0042	0:15	Yes	SD 29	Smoke Detector	Pass	SE Open Area
I-BL-08-0002.S0043	0:15	Yes	SD 28	Smoke Detector	Pass	SE Open Area
I-BL-08-0002.S0044	0:15	Yes	SD 27	Smoke Detector	Pass	SE Open Area
I-BL-08-0002.S0045	0:15	Yes	SD 26	Smoke Detector	Pass	Main Entrance
I-BL-08-0002.S0046	0:15	Yes	SD 25	Smoke Detector	Pass	Office # 15
I-BL-08-0002.S0047	0:15	Yes	SD 24	Smoke Detector	Pass	Office # 14
I-BL-08-0002.S0048	0:15	Yes	SD 23	Smoke Detector	Pass	Office # 13
I-BL-08-0002.S0049	0:15	Yes	SD 22	Smoke Detector	Pass	Office # 12
I-BL-08-0002.S0050	0:15	Yes	SD 21	Smoke Detector	Pass	Office # 11
I-BL-08-0002.S0051	0:15	Yes	SD 20	Smoke Detector	Pass	Office # 10
I-BL-08-0002.S0052	0:15	Yes	SD 19	Smoke Detector	Fail	Office # 9
I-BL-08-0002.S0053	0:15	Yes	SD 18	Smoke Detector	Pass	Office # 8
I-BL-08-0002.S0054	0:15	Yes	SD 17	Smoke Detector	Pass	Office # 6
I-BL-08-0002.S0055	0:15	Yes	SD 16	Smoke Detector	Pass	Office # 5
I-BL-08-0002.S0056	0:15	Yes	SD 15	Smoke Detector	Pass	Office # 4
I-BL-08-0002.S0057	0:15	Yes	SD 14	Smoke Detector	Pass	Office # 3
I-BL-08-0002.S0058	0:15	Yes	SD 13	Smoke Detector	Pass	Office # 1
I-BL-08-0002.S0059	0:15	Yes	SD 12	Smoke Detector	Pass	SE Employee Closet
I-BL-08-0002.S0060	0:15	Yes	SD 11	Smoke Detector	Pass	SE Employee Storage Closet
I-BL-08-0002.S0061	0:15	Yes	SD 10	Smoke Detector	Pass	SE Bathroom
I-BL-08-0002.S0062	0:15	Yes	SD 09	Smoke Detector	Pass	SE Bathroom
I-BL-08-0002.S0063	0:15	Yes	SD 08	Smoke Detector	Pass	Phone Closet C
I-BL-08-0002.S0064	0:15	Yes	SD 07	Smoke Detector	Pass	SE Bathroom
I-BL-08-0002.S0065	0:15	Yes	SD 06	Smoke Detector	Pass	SE Bathroom
I-BL-08-0002.S0066	0:15	Yes	SD 05	Smoke Detector	Fail	SE Closet
I-BL-08-0002.S0067	0:15	Yes	PS 01	Pull Station	Fail	East Employee Entrance
I-BL-08-0002.S0068	0:15	Yes	PS 02	Pull Station	Pass	East Main Exit
I-BL-08-0002.S0069	0:15	Yes	PS 03	Pull Station	Pass	West Main Exit
I-BL-08-0002.S0070	0:15	Yes	PS 04	Pull Station	Pass	NW Courtyard Exit

**Total Hours: 17.50****Bob Lee Activity Totals**

<b>Sub Activity Totals:</b>	<b>21.50</b>
<b>Primary Activity Totals:</b>	<b>2.50</b>
<b>Total:</b>	<b>24.00</b>

Project Activity Totals	
Sub Activity Totals:	21.50
Primary Activity Totals:	2.50
Total:	24.00
2 of 2 Complete	